

GOLDFIELD TOWN WATER (NV0000072) - Arsenic Running Annual Average (RAA) (Q3 2021)

Year	Quarter	Date Sample Taken	Arsenic Analytical Report Result (µg/L)	Quarterly Average of Arsenic Analytical Report Results (µg/L)	Arsenic Running Annual Average (RAA) (µg/L)
2021	3	9/8/2021	3.27	7.00	5.78
		8/4/2021	10.40		
		7/7/2021	7.34		
	2	6/7/2021	3.02	4.75	5.33
		5/5/2021	5.28		
		4/7/2021	5.94		
	1	3/8/2021	6.91	5.89	14.67
		2/8/2021	7.16		
		1/5/2021	3.60		
2020	4	12/8/2020	2.86	5.49	15.94
		11/9/2020	3.64		
		10/7/2020	9.98		
	3	9/9/2020	5.36	5.18	15.29
		8/5/2020	5.00		
	2	5/6/2020	42.10	42.10	17.64
	1	3/9/2020	13.80	10.97	8.46
		2/5/2020	0.00		
		1/8/2020	19.10		
2019	4	12/9/2019	1.82	2.90	9.23
		11/6/2019	3.89		
		10/8/2019	3.00		
	3	9/5/2019	14.00	14.61	13.98
		8/14/2019	24.10		
		7/29/2019	5.72		
	2	6/5/2019	5.36	5.35	13.58
		5/29/2019	5.33		
	1	3/20/2019	6.18	14.07	14.49
3/7/2019		7.53			
1/25/2019		28.50			
2018	4	12/28/2018	21.90	21.90	12.73
	3	9/27/2018	13.00	13.00	9.25
	2	5/24/2018	9.00	9.00	8.75
	1	2/22/2018	7.00	7.00	7.75
2017	4	10/4/2017	8.00	8.00	8.00
	3	8/8/2017	11.00	11.00	
	2	5/25/2017	5.00	5.00	
	1	2/23/2017	8.00	8.00	